

FITNESS CERTIFICATE

To be filled by the Inspecting Officer (Asst. Engineer)
(Re:G.O. Ms.20/70/PWD Dt.23-01-1970)

1 Name of the Officer	Jisha M V
2 Name of the School	Bharathiya vidya Bavan's School
3 Location With Name of Education District/Sub.District.	Valiyakunnu ,Kuttippuram, Tirur
4 Classification of Buildings as specified in Column 4 of the Application for Fitness Certificate and size.	RCC Roof
	1. 8.60 x 6.10 x 3.70m - 5 nos - GF
	2. 8.60 x 6.10 x 3.70m - 5 nos - FF
	3. 6.50 X 6.00 X 3.70M - 4 Nos - GF
5 Period for Which the Certificate is Issued	2026-2027
6 Nature of defects,if any	
a) Foundation and basement	Nil
b)Superstructure	Nil
c)Doors and windows	Nil
d)Wood work wrought and put up	Nil
e)Roof	Nil
f)Flooring	Nil
g)Miscellaneous (Cracks,etc)	Nil
7 Any Major defects noticed which will render the Building unsafe in any manner	Nil
8 Whether maintainance works have been done properly	Yes
9 Whether the Structure is sound for conducting classes	Yes, sound and fit for conducting classes under normal wind and weather condition.

Note:1.The stability of the structure should be examined also with reference to location,altitude,intensity of wind,exposure of flood etc. 2.Any additional observations if deemed necessary for the Certificate may be furnished seperately with this Certificate.

Note:2.This certificate is applicable oniy to the safety related civil constructions. Separate certificates as the health order No :M3/347/2019-Health and family welfare dated 09/11/2025 shall be obtained frm the concerned department.

Note:3.This certificate is only for structural safety of class rooms mentioned in this certificate. It doesn't matter safety in kitchens , laboratories etc.

Note:4.For new constructions in the school compound should be itimated and permit shall be obtained from LSGL. Safety measures such as barricades must be must be ensured.

CERTIFICATE

Certified that the School building was inspected by me on 20/06/2026 and found to be FIT to conduct classes,for the period 2026-27 for the reasons stated above.

Place: Irimbiliyam
Date:20/06/2026




ASSISTANT ENGINEER
LSGD SECTION
IRIMBILIYAM GRAMA PANCHAYAT
P.O. VALIYAKUNNU, Pin: 676 552