



KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LABORATORY

MULLASSERY, PVARATTY, THRISSUR-680507

Telephone No - 0487-2997763, E-mail - kwa.qcsd.pvty@gmail.com

NABL Recognized Sub Divisional Level Government Drinking Water Testing laboratory

(Certificate No: NABL - DWT-00982)

TEST REPORT

Test Report. No.: KWA/QCSDL/PVTY-TSR002103/2026

Report Date :03/08/2026


BLOOMING BUDS BETHANIA ENGLISH SCHOOL MARATHANCODE PO 680601 MOB: 7559969881			1. Date of Receipt : 29/07/2026		
			2. Sampling done by : The Customer		
			3. UID No of Sample: KWA/QCSDL/PVTY-TSR002103/2026		
			4. Source of Sample: OPEN WELL		
			5. Sample condition : Fit for requested tests		
			6. Name of sample : Drinking Water		
			7. Purpose of test : Commercial		
			8. Sample Quantity : 2 Litre		
			9. Test Performing Dates		
			From: 29/07/2026		To: 29/07/2026
Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500 - 2012	Result
1	Turbidity	(NTU)	IS 3025 (part 10) - 2023 Nephelometric method	1	1.39
2	pH at 25°C		IS 3025 (part 11) - 2022 Electrometric method	6.5 to 8.5	6.45
3	Total Hardness (as Ca CO ₃)	(mg/litre)	IS 3025 (part 21)-2009 (R. 2019) EDTA titration method	200	40.64
4	Chloride (as Cl)	(mg/litre)	IS 3025 (part 32) - 1988 (R. 2019) Argentometric titration	250	14.78

Remarks:-

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by: 

* End of Report *

Authorized By: 

Issue Date 10/01/2023	Issue No:2	KWA/QCSDL/PVTY-TSR/R.No:6
Rev.No: 00	Rev Date:00	Page 1 of 3



Technical Manager,
Quality Control Sub District Laboratory
Kerala Water Authority
Mullassery, Pavaratty - 680 507



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY

MULLASSERY,PAVARATTY, THRISSUR-680507

Telephone No - 0487-2997763, E-mail - kwa.qcsdl.pvty@gmail.com

Test Report

Test Report. No : KWA/QCSDL/PVTY-TSR002103/2026

Report Date :03/08/2026

CUSTOMER NAME & ADDRESS BLOOMING BUDS BETHANIA ENGLISH SCHOOL MARATHANCODE PO 680601 MOB: 7559969881			1. Date of Receipt : 29/07/2026		
			2. Sampling done by : The Customer		
			3. UID No.of Sample : KWA/QCSDL/PVTY-TSR002103/2026		
			4. Source of Sample : OPEN WELL		
			5. Sample condition : Fit for requested tests		
			6. Name of sample : Drinking Water		
			7. Purpose of test : Commercial		
			8. Sample Quantity : 2 Litre		
			9. Test Performing Dates From : 29/07/2026 To: 29/07/2026		
Sl. No.	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500 - 2012	Result
1	Electrical Conductivity	(micro mhos/cm)	IS 3025 (part 14) - 2013 (R. 2019) Electrometric method	-	95.71
2	Iron (as Fe)	(mg/litre)	IS 3025 (part 53) - 2024 1,10 Phenanthroline method	1.0	0.48
3	Nitrate (as NO ₃)	(mg/litre)	Phenol Disulphonic Acid Method.	45	11.72

Remarks:-

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by:



*** End of Report ***

Authorized By:

Technical Manager,
Quality Control Sub District Laboratory
Kerala Water Authority
Mullassery, Pavaratty - 680 507

Issue Date: 10/01/2023	Issue No:2	KWA/QCSDL/PVTY-TSR/R.NO:6
Rev.No: 00	Rev Date: 00	Page 2 of 3



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY

MULLASSERY,PAVARATTY, THRISSUR-680507

Telephone No - 0487-2997763, E-mail -kwa.qcsd.pvty@gmail.com

Test Report


Test Report. No : KWA/QCSDL/PVTY-TSR002320/2026

Report Date:19/08/2026

Customer Name & Address			1. Date of Receipt : 14/08/2026	
BLOOMING BUDS BETHANIA ENGLISH SCHOOL MARATHANCODE PO 680601 MOB: 7559969881			2. Sampling done by : The Customer	
			3. UID No of Sample: KWA/QCSDL/PVTY-TSR002320/2026	
			4. Source of Sample : OPEN WELL	
			5. Sample Condition : Fit for requested tests	
			6. Name of Sample : Drinking Water	
			7. Purpose of test : Commercial	
			8. Sample Quantity :100ml	
			9. Test Performing Dates	
			From : 17/08/2026	
			Test Method	Result
1	Coliforms	Shall not be detected / 100ml	IS 15185 : 2016 ISO 9308 - I : 2014	100
2	E. Coli	Shall not be detected/ 100ml	IS 15185 : 2016 ISO 9308 - I : 2014	NIL

Remarks:-

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.



Technical Manager,
Quality Control Sub District Laboratory
Kerala Water Authority
Mullassery, Pavaratty - 680 507

*** End of Report ***

Issue Date: 10/01/2023	Issue No:2	KWA/QCSDL/PVTY-TSR/R.NO:6
Rev.No: 00	Rev Date: 00	Page 3 of 3