

FITNESS CERTIFICATE

To be filled by the Inspecting Officer (Asst. Engineer)

(Re: G.O. Ms. 20/70/ PWD Dt. 23 - 01 -1970)

- Name of the School** B.M.M. English Mediam (Senior Secondary) School
Pothanpuram P O, Pampady, Kottayam, Kerala -
686502
1. Name of the Officer : SHERIN AMBILY JAMES
2. Location : Meenadam GP, Kottayam
3. Period for which the certificate is : 2025 - 2026
4. Types of building : (1)Permenant RCC Building.
Old Block - BMM Minor Scholar Inn - Building No:
VIII(8)/297:
GF : 816.35 M2, FF : 806.80 M2,

(2)Permenant RCC Building. New Block - Three
Storied Building No: VIII(8)/298 :
BF : 62.23 M2, GF : 759.99 M2, FF : 759.99 M2,
SF: 273.50 M2,

(3) Permenant RCC Building. Administrative Block:
Building No: VIII(8)/298 : GF : 677.92 M2 &
619.19M2
5. Nature of defect if any
a) Foundation and basement :Nil
b) Superstructure :Nil Except a few minor hair cracks.
c) Doors and windows :Nil
d) Wood work wrought and put up :Nil
e) Roof Nil
f) Flooring :Nil
g) Miscellaneous (Cracks if any) : Small type of honeycombing was found in some
location of structures. No Major defects noticed at the
time of inspection.
6. Any Major defects notices which will
render the building unsafe in any :Nil
7. Whether maintenance works have
been done properly :Yes
8. Whether the structure is sound or not
for conducting classes :The building is safe under normal weather and wind
condition. Structure is Sound and Fit.

Note:- 1. The stability of the structure should be examined also with reference to location
altitude intensity of wind exposure or flood etc.

2. Any additional observation if deemed necessary for the certificate may be furnished
separately with the certificate.


CERTIFICATE

Certified that the School was inspected by me on 22/03/2025 and found to be **fit**
to conduct classes for the period 2025-2026 for the reason stated above.

Place: Meenadam
Date: 22/03/2025



(Seal)


Assistant Engineer

ASSISTANT ENGINEER
LID & EW Section
Meenadam Grama Panchayath