

KERALA STATE HEALTH DEPARTMENT

PRIMARY HEALTH CENTER, MANALUR

No. 106/26

Dated 12/3/2026

SANITARY CERTIFICATE

1. LSGD-Circular No.66562/Rc3/12 LSGD/DT.10.01.2013
2. Service Act No. O-m 3/30892/12DHS/DT. 60.06.014
3. No.16203/ A-R (2) 1/2013 /TVM/ DT. 8.4.2014

The Health inspector of this establishment has conducted inspection on 12/03/26 at the Bharatiya Vidya Bhavan's School situated in Manalur Panchayat Building no.VII/72, 73, Thrissur district. The said unit is working in the name of Principal, Bharatiya Vidya Bhavan's School, and Kanjani. When the unit and surroundings were inspected, the sanitary conditions found satisfactory. The sanitary certificate is issued subject to the following terms and conditions.

1. The establishment should function without causing nuisance to the public.
2. Wastes should be disposed scientifically without causing issues to public health.
3. Water bodies are to be maintained without causing communicable diseases.
4. The establishment must not cause any kind of water, air or noise pollution.
5. The establishment and surroundings are to be protected from diseases.
6. The employees should be free from communicable diseases.
7. Sign boards of Tobacco, Pan should be displayed and also ensure that the establishment is free from usage of Tobacco.
8. The medical officer of the nearest primary health center should be duly informed if migrant workers are working in the establishment.
9. Plastic waste should be scientifically disposed off.
10. The establishment should follow the Public Health MHP ACT, Panchayat Raj ACT and statues.
11. Any future development activities should be subject to the permission from this office.
12. If it is observed that any of the above stipulations are violated, this certificate will be cancelled without prior notice.



HEALTH INSPECTOR

PRIMARY HEALTH CENTRE

MANALUR

HEALTH INSPECTOR
FAMILY HEALTH CENTRE, MANALUR
P.O. KANDASSANKADAVU
PIN 680613



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY

THALIKULAM, THRISSUR

NABL Recognized Sub Divisional Government Drinking Water Testing Laboratory

(Certificate No. : NABL-DWT - 00983)

Telephone No - 0487-2997762, E-mail - kwa.qcsd.tkml@gmail.com

Test Report

Test Report. No.:KWA/QCSDL/TKLM-TSR/000695/2026

Report Date :13/03/2026

Customer Name & Address			1. Date of Receipt :11/03/2026		
Bharatiya Vidhya Bhavans School P O Kanjani			2. Sampling done by : The Customer		
			3. UID No of Sample:KWA/QCSDL/TKLM-TSR/S-000695/26		
			4. Source of Sample :Open Well		
			5. Sample condition : Good		
			6. Name of sample : Water		
			7. Purpose of test : Licence		
			8. Sample Quantity : 2 Litre		
			9. Test Performing Dates		
			From :11/03/2026		To :12/03/2026
	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500 - 2012	Result
1	Turbidity	(NTU)	IS 3025 (part 10) - 2023 Nephelometric method	1	0.77
2	pH at 25°C		IS 3025 (part 11) - 2022 Electrometric method	6.5 to 8.5	6.25
3	Total Hardness (as Ca CO ₃)	(mg/litre)	IS 3025 (part 21)-2009 (Reaffirmed. 2023)EDTA titration method	200	11.58
4	Chloride (as Cl)	(mg/litre)	IS 3025 (part 32) - 2025 Argentometric titration	250	5.83

Remarks:-

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by:

Authorized By

* End of Report *

Issue Date 10/01/2023	Issue No:2	KWA/QCSDL/TKLM-TSR/R.No:6
Rev.No: 00	Rev Date:00	Page 1 of 1



Technical Manager,
Quality Control Sub District Laboratory,
Kerala Water Authority
Thalikulam - 680 569



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY
THALIKULAM, THRISSUR

Telephone No - 0487-2997762, E-mail - kwa.qcsd.tklm@gmail.com

Test Report

Test Report. No : KWA/QCSDL/TKLM-TSR/000695/2026

Report Date :13/03/2026

Customer Name & Address			1. Date of Receipt :11/03/2026		
Bharatiya Vidhya Bhavans School P O Kanjani			2. Sampling done by : The Customer		
			3. UID No.of Sample : KWA/QCSDL/TKLM-TSR/S-000695/26		
			4. Source of Sample : Open Well		
			5. Sample condition : Good		
			6. Name of sample : Water		
			7. Purpose of test : Licence		
			8. Sample Quantity : 2 Litre		
			9. Test Performing Dates		
			From :11/03/2026 To :12/03/2026		
Sl. No.	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500 - 2012	Result
1	Electrical Conductivity	(micro mhos/cm)	IS 3025 (part 14) - 2013 (Reaffirmed 2023) Electrometric method	-	19.11
2	Iron (as Fe)	(mg/litre)	IS 3025 (part 53) - 2024 1,10 Phenanthroline method	1.0	0.09
3	Nitrate (as NO ₃)	(mg/litre)	PDS Phenol Disulphonic acid Method	45	0.26

Remarks:-

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by:

Authorized By:

Technical Manager,
Quality Control Sub District Laboratory
Kerala Water Authority
Thalikulam - 680 569

*** End of Report ***

Issue Date: 10/01/2023	Issue No: 2	KWA/QCSDL/TKLM-TSR/R.NO:6
Rev.No: 00	Rev Date: 00	Page 1 of 1



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY
THALIKULAM, THRISSUR

Telephone No - 0487-2997762, E-mail -kwa.qcsd.tklm@gmail.com

Test Report

Test Report. No : KWA/QCSDL/TKLM-TSR/000695/2026

Report Date:13/03/2026

Customer Name & Address			1. Date of Receipt : 11/03/2026	
Bharatiya Vidhya Bhavans School P O Kanjani			2. Sampling done by : The Customer	
			3. UID No.of Sample : KWA/QCSDL/TKLM-TSR/S-000695/26	
			4. Source of Sample : Open Well	
			5. Sample Condition : Good	
			6. Name of Sample : Water	
			7.Purpose of test : Licence	
			8. Sample Quantity : 100ml	
			9. Test Performing Dates	
			From :11/03/2026	To : 13/03/2026
			Test Method	Result
1	Coliforms	Shall not be detected / 100ml	IS 15185 : 2016 (Reaffirmed 2021)	230
2	E. Coli	Shall not be detected/ 100ml	IS 15185 : 2016 (Reaffirmed 2021)	NOT DETECTED


Remarks:-

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.



Reviewed by:




Authorized By:

Technical Manager,
Quality Control Sub District Lab
Kerala Water Authority
Thalikulam - 680 569

Issue Date: 10/01/2023	Issue No:2	KWA/QCSDL/TKLM-TSR/R.NO:6
Rev.No: 00	Rev Date: 00	Page 1 of 1