

FITNESS CERTIFICATE

(To be filled by the Inspecting Officer (Asst. Engineer) (Re: G.O. Ms. 20/70/ PWD Dt. 23 - 01 -1970))

1. Name of the Officer : VANI N V
2. Name of the School : Bharathiya Vidhya Bhavan's School, Kanjany
3. Location with name of Education District/ Sub. District : NA
4. Classification of Building as specified in column 4 of the application for fitness certificate and size.

RCC building – Multi storied:

{	West Block GF - 6.00x6.00x3.00 - 6 Nos
	FF - 6.00x6.00x3.00 - 6 Nos
	6.00x3.00x3.00 - 1 Nos
	East Block GF - 6.00x6.00x3.00 - 6 Nos
	FF - 6.00x6.00x3.00 - 6 Nos
	6.00x3.00x3.00 - 1 Nos
	Principal Block - 6.00x6.00x3.00 - 4 Nos

5. Period for which the certificate is issued: 2026-27 Academic year

6. Nature of defects, if any

- | | | |
|---------------------------------|---|-----|
| a) Foundation and basement | } | Nil |
| b) Superstructure | | |
| c) Doors and Windows | | |
| d) Wood work wrought and put up | | |
| e) Roof | | |
| f) Flooring | | |
| g) Miscellaneous (Cracks, etc.) | | |

7. Any major defects noticed that will render the building unsafe in any manner: Not found at the time of inspection.
8. Whether maintenance works have been done properly: Yes.
9. Whether the structure is sound or not for conducting classes: Sound for conducting classes under normal wind and weather conditions. (Except First Floor area of Principal Block Which is covered with Sheet Roof, Extended area of West Block Building which is found to be unauthorised.)

Note: 1. The stability of the structure should also be examined with reference to location, altitude, intensity of wind, exposure to flood, etc.

2. Any additional observations, if deemed necessary for the certificate, may be furnished separately with this certificate.

CERTIFICATE

Certified that the school building was inspected by me on 30.05.2026 and found to be fit/unfit to conduct classes, for the period 2026-27 academic year, for the reasons stated above, with the following conditions

1. This certificate applies only to safety related to civil construction. Separate certificates for fire safety and safety of electrical installations, electrical lines/conduits and Safety of LPG connection shall be obtained from the concerned departments.
2. Maintenance of the school premises should be done periodically. The inspecting officer is not liable for any unfortunate accidents in the school premises due to lack of security or periodic maintenance.
3. This certificate is only for the structural safety of the classrooms mentioned in this certificate. It does not cover safety in laboratories, kitchens, etc.
4. For any new construction in the school compound, it should be intimated and a permit should be obtained from LSGI. Safety measures such as barricades must be ensured.
5. Internal wiring of the school should be verified by a registered /Approved Electrician before conducting classes
6. This fitness certificate is issued provisionally based on circular No: GEDN-M1/188/2025-G.EDN by General Education (M) Department Thiruvananthapuram :13/05/2026 and Circular No -LSGD/2037/2026-EW3, Chief Engineer, Principal Directorate, LSGD. The head of the institution should follow all the instructions in Circular No M3/347/2019- HEALTH, dated 09/11/2025, Health & Family Welfare (M) Department, Government of Kerala and copies of the necessary NOC/Verification reports, after rectification works in schools, if any, should be handed over to this office within one month.

Place: Karamuck

Date: 30.05.2026



(Office Seal)

Assistant Engineer

Assistant Engineer
LSGD Section, Manaloor