

PRIMARY HEALTH CENTRE

Adat, Puranattukara P.O, Pin-680551, Ph: 0487-2304928, Email: phcadat@gmail.com

CERTIFICATE OF SANITATION AND CLEANLINESS

No. 07/2025.



Sir,

I here by certify that sanitation and cleanliness facilities of the under mentioned institution is found satisfactory at the time of my visit on 13.06.2025.

Name of the Panchayat	: Adat
Name of the Village	: Adat
Survey / Resurvey number	: 5/P,17/2P
Ward number	: 18
Building number	: 231-239
Ownership	: Managing Trustee, Bharathiya Vidya Peedam Sr.Sec. School, Udalakkavu P. O, Adat ,Thrissur (Dist), Pin-680551
Name of School	: Bharathiya Vidya Peedam Sr. Sec. School Udalakkavu (P.O) Adat. Thrissur (Dist), PIN 680551

This certificate has been awarded to the school for the functioning of the year 2025-2026 as per the rules and regulations.

This certificate will be cancelled in case of the offence of the any one of the acts of sanitation and cleanliness mentioned in 1955- Travancore – Kochi public health rule.

Puranattukara

Signature

Date : 25-06-2025.

HEALTH INSPECTOR
PHC, ADAT
HEALTH INSPECTOR
PHC ADAT

Mr. MANOJ K V M.Sc.B.Ed.,SET.
PRINCIPAL
BVP SR.SEC.SCHOOL, ADAT P.O.
THRISSUR-680551, KERALA
SCHOOL CODE: 76067
CBSE AFFILIATION No: 331152
E-mail: principalbvpschool@gmail.com

Maria Complex, Opp. Majestic Hyper Market, Paravattani, Thrissur-680 655, Kerala
Tel.: 94470 23229, 90488 27704, 95448 69122 (Office) jalashudhifabs2020@gmail.com



Approved by Kerala State Pollution Control Board

Approval No: PCB/LAB/C32/2020

TEST REPORT

Test Report No: JSL/TCR/2705202501

Date of issue: 27-05-2025

Customer Name & Address : M/s. BVP School, Adat

Date of sample collection : 20/05/2025

Type of Sample: Filter water

Date of Completion of Analysis: 27/05/2025

Mode of Sampling: Supplied by Party

TEST RESULTS						
Sl No	Parameter	Test method APHA	Unit	Acceptable Limit	Permissible Limit	Result
A	Physical Examination					
1.	Taste and odour	2160 A	-	Agreeable	Agreeable	Agreeable
2.	Electrical conductivity	2510 B	µS/cm	-	-	30
3.	Turbidity	2130 B	NTU	1	5	0.1
4.	Total Dissolved solids	2540 C	mg/L	500	2000	16
B	Chemical Examination					
5.	Ph	4500 H ⁺ B	-	6.5-8.5	No relaxation	6.52
6.	Total Alkalinity	2320 B	mg/L	200	600	14
7.	Total Hardness as CaCO ₃	2340 C	mg/L	200	600	20
8.	Calcium Hardness as CaCO ₃	3500 Ca B	mg/L	-	-	8
9.	Magnesium Hardness as CaCO ₃	3500 Mg B	mg/L	-	-	12
10.	Calcium	3500 Ca B	mg/L	75	200	3.20
11.	Magnesium	3500 Mg B	mg/L	30	100	2.91


Mr. MANOJ K V M.Sc., B.Ed., SET.
PRINCIPAL
BVP SR. SEC. SCHOOL, ADAT P.O.
THRISSUR-680 655, KERALA
SCHOOL CODE: 76067
CBSE AFFILIATION No: 331152
E-mail: principalbvpsschool@gmail.com

Sl No	Parameter	Test method APHA	Unit	Acceptable Limit	Permissible Limit	Result
12.	Chloride	4500 Cl ⁻ B	mg/L	250	1000	20
13.	Sulphate	4500 SO ₄ E	mg/L	200	400	0.24
14.	Ammonia as N	4500 NH ₃ F	mg/L	0.5	No relaxation	0.16
15.	Iron	3500 Fe B	mg/L	0.3	No relaxation	0.15
C	Bacteriology					
16.	Total Coliform	9222 B	cfu/100 ml	Shall not be detectable in any 100 ml sample		NIL
N	Fecal coliform (Thermotolerant)	9222 D	cfu/100 ml			NIL

REMARKS

- All the parameters are within the limit

For JalaShudhi Laboratories

Analyst

[Signature]

A. Suresh, T.R.



Note: The above results are related only to the sample submitted for the analysis. The test report shall not be reproduced except in full, without the written approval of the laboratory

[Signature]
Mr. MANOJ K V M.Sc., B.Ed., SET.
 BVP SR. SEC. SCHOOL, ADAT P.O.
 THRISSUR-680 551, KERALA
 SCHOOL CODE: 76067
 CBSE AFFILIATION No: 931152
 E-mail: principalbvpschool@gmail.com