APPENDIX - XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 145/2024-25 Dated: 08/04/2024

It is certified that an inspection team headed by K. Subrahmaniy, Health Inspector (Name of Officers with designation) from F.H.C Angadippuram, Dt. Malappuram (Name of Department/ Office) inspected the Darul Falah English school Poopparas (Name & Address of the school) on 2/4/2024 (date of inspection) and found that the Darul Falah English school (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 2024 March to 2025 Febry

Signature with Seal: .....

Name : Subrahmaniy K

Designation : Health Inspector

Name & Address of the Office / Department : .....

To

Principal

Darul Falah English school, Poopparas, Ayur

(Name & Address of the Institution)

*** The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.**

Manager,
Darul Falah English School
Poopalam, Valamboor
Dt. Malappuram, Kerala

Shaukathali T
Principal
Darul Falah English School
Poopalam, Valamboor (P.O.) 679325
Malappuram Dist. Kerala

SIGNATURE SOLUTIONS
ISO 9001:2015

SIGNATURE SOLUTIONS

(Approved by Pollution Control Board, Government of Kerala)
(Approval No. PCB/LAB/C21/2018)
2nd Floor, Eva Tower, Mannarkad Road,
Perinthalmanna, Malappuram Dt. 9061192481
www.signaturesolutions.in, signaturepmna@gmail.com

WATER ANALYSIS REPORT

Name & Address	Darul Falah School. Poopalam. School Code : 75275	
Source of Sample	Bore Well	
Sampling Done by	Party	
Code No. of Sample	117	
Sample Received on	23/02/2024	
Sample Performance From	23/02/2024 to 28/02/2024	
Type of Analysis	Physical, Chemical	Bacteriology

Sl. No.	*Characteristics*	*Method of Analysis*	*Result*	*Desirable Limit*
1.	Color	VISUAL	Colorless	
2.	Odor	IS:3025	Agreeable	Agreeable
3.	Turbidity	IS:3025	BDL	5 NTU
4.	pH	IS:3025	6.26	6.5 – 8.5
5.	Electrical Conductivity	IS:3025	128µS/cm	-
6.	Total Dissolved Solids	IS:3025	71mg/l	500mg/l
7.	Alkalinity	IS:3025	32mg/l	200mg/l
8.	Total Hardness	IS:3025	68mg/l	200mg/l
9.	Calcium as Ca	IS:3025	11.2mg/l	70mg/l
10.	Magnesium as Mg	IS:3025	9.76mg/l	30mg/l
11.	Chlorides	IS:3025	20mg/l	250mg/l
12.	Ammonia	IS:3025	BDL	0.5mg/l
13.	Sulphate	IS:3025	7.0mg/l	200mg/l
14.	Iron	IS:3025	0.04mg/l	0.3mg/l
15.	Fluoride	IS:3025	0.1mg/l	1mg/l
16.	Coliforms	IS:3025	ABSENT	ABSENT
17.	E.coli	IS:3025	ABSENT	ABSENT

***BDL: Below Detectable Limit.**
Opinion of Analyst: Satisfactory.

Manager,
Darul Falah English School
Poopalam, Valamboor
Dt. Malappuram, Kerala

Analyst

Shaukathali T
Principal
Darul Falah English School
Poopalam, Valamboor (P.O.) 679325
Malappuram Dist. Kerala

Date : 28-02-2024