



KERALA WATER AUTHORITY

QUALITY CONTROL DISTRICT LABORATORY

KIZHAKKUMPATTUKARA, THRISSUR
Telephone No - 0487-2338380, E-mail -kwa.qc.tsr@gmail.com

Test Report

Test Report. No : KWA/QCDL/TSR/3494/2024

Report Date : 18.05.2024

Customer Name & Address Guardian Angels English Medium School, P.O Kainoor, Puthur, Thrissur, Mob:9497457992			1. Date of receipt : 15.05.2024 2. Sampling done by : The Customer 3. UID No.of Sample: KWA/QCDL/TSR/S-003494/2024 4. Source of sample : Borewell 5. Sample condition : Good 6. Name of sample : Water 7. Sample Quantity :100ml 8. Test Performing Dates From : 15.05.2024 To : 17.05.2024	
Sl. No.	Parameters	Acceptable limits as per-IS 10500-2012	Test Method	Result
1	Total Coliforms	Shall not be detected / 100ml	IS 15185 : 2016 ISO 9308 - 1 : 2014	Not detected
2	E. Coli	Shall not be detected/ 100ml	IS 15185 : 2016 ISO 9308 - I : 2015	Not detected

Remarks:- Coliforms and E.Coli bacteria not detected.

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by:



Authorized By **Raghu M K**
 Quality Manager,
 Quality Control District Laboratory
 Kerala Water Authority
 Thrissur - 689 905


* End of Report *

KWA/QCDL/TSR-R-No:6	Issue No:2	Issue Date 10/01/2023
Rev.No: 00	Rev Date: 00	Page 1of 1

SANITARY CERTIFICATE

I, Suresh . C. K , Health Inspector Family Health Centre Puthur inspected Guardian Angels English Medium School functioning in building No.II/610 of Puthur Grama Panchayath on 25/5/24 and the sanitary arrangements provided were found satisfactory .

Vettukad,
25/5/24 .


HEALTH INSPECTOR
PRIMARY HEALTH CENTRE
PUTHUR, THRISSUR - 14

