



KODUNGALLUR MUNICIPALITY

Kodungallur P.O., Thrissur Dist - 680 664
Phone: 0480-2802341, kdmty@yahoo.com

PHI-4087338-2028

Date: 04/06/2028

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Health Inspector Sri. Abish K. Antony & Public Health Inspector Srimal. Amina Beevi R from Municipal Office, Kodungallur inspected the GURUSREE PUBLIC SCHOOL(XII,15A, 15B,15C,15D) P.O Pulut , Kodungallur, Thrissur District on 15/05/2028 date of inspection and on the basis of water Test Report bearing no AXL/AQUAWTR/2349-2028 dated 9/05/2028 Narantra Maraya Sevana Kendham (NRMSA) (PMVSr) Supported by Kerala Fisheries Department certified that the GURUSREE PUBLIC SCHOOL has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the central/state/UT Govt.

The above valid for a period of one year




Clean City Manager
Kodungallur Municipality
**CLEAN CITY MANAGER
PUBLIC HEALTH & ENVIRONMENT
MANAGEMENT WING, LSGD
KODUNGALLUR MUNICIPALITY**



APPROVAL NO: PCB/LAB/C15/2023

NAVARATNA MATSYA SEVANA KENDRAM (N.R.M.S.K)

[P M M S Y] Supported by

Kerala Fisheries Department

P. Venkatar, S.M Puram,

Thiruvananthapuram, Kerala-695011.

Ph: 9287924215, 9956889611

e-mail id: navaratnamatsyasevakendram@gmail.com

www.gommonaqua.in

TEST REPORT

Test Report No. : ASL/AQUAWTR/2349-2023

Report issue date: 09/05/2023

Name & address of the Customer: Guruvayur Public School, Pullat P O, Kodungallur, Pin: 686553, School code:75434	Sample Name Provided by the Customer: PURIFIED WATER
Sample ID : WTR/2349/2023	Sample submitted by : Customer
Sampling date (provided by customer): 08/05/2023	Sample quantity : 1L
Sample receipt date : 08/05/2023	Customer Sample ID if any : Nil
Analysis performing date : 08/05/2023- 09/05/2023	Description & condition of the sample: Colorless liquid & received under good condition.

Sl NO	PARAMETERS	METHOD OF ANALYSIS	UNIT	ACCEPTABLE LIMIT as per IS 30500- 2012	RESULTS
PHYSICAL PARAMETERS					
1	pH	IS 3025: 1983 (part 13)	-	6.5-8.5	8.26
2	Colour	IS 3025: 1983 (part 5)	-	Agreeable	Agreeable
3	Turbidity	IS 3025: 1984 (part 30)	NTU	1	0.3
4	Total Dissolved Solids	IS 3025: 1984 (part 16)	mg/l	500	16.5
5	Conductivity	IS 3025: 1983	µS/cm		48.7
CHEMICAL PARAMETERS					
6	Alkalinity	IS 3025: (part 23)	mg/l	200	24
7	Chloride	IS 3025: (part 32)	mg/l	250	14.46
8	Total Hardness	IS 3025: (part 17)	mg/l	300	8
9	Calcium	IS 3025 (Part 40)	mg/l	75	0.86
10	Magnesium	IS 3025: (part 40)	mg/l	30	0.37
11	Salinity				0.02
12	Nitrate	IS 3025 (part 34)	mg/l	45	0
13	Nitrite	IS 3025 (Part 34)	mg/l	0.02	0
14	Iron	IS 3025 (Part 54)	mg/l	0.4	0
15	Ammonium		mg/l	Maximum 0.5	0

BACTERIOLOGICAL ANALYSIS

76	F coli	IS 1623: 1981	CFU/100ml	Shall not detectable in any 100ml. of sample	Absent
17	Coliforms	IS 1623: 1981	CFU/100ml		Absent

Remarks: From this analysis all values are within the acceptable limit. This water is fit for all purposes.

Analysed by,

NAVAKUTNA MATSYA SEVANA KENDRAM

TESTING LABORATORY

CHEMIST

MICROBIOLOGIST

Authorized Signatory



Dr. AKHILA MOLE M.A.
B.Sc., PhD (Microbiology)
MANAGING DIRECTOR
NAVAKUTNA MATSYA SEVANA KENDRAM
PULLUT P.O., KODUNGALLUR
TELEPHONE NO: 680663

Principal

Guru Sree Public School Senior Secondary
P.O. Pullut, Chappara, Kodungallur

