



## Water Quality Test Payment Receipt

Applicant Name : HOLY FAMILY CONVENT PUBLIC SCHOOL

Application ID: QUA\_206327

Address : BADIADKA PERDALA P.O KASARAGOD DT 671551

Phone : 9496293239

Payment Date : 06-Mar-2025

Lab Name : District Lab Vidyanagar Kasargod

Bank Transaction ID : BBBC12T0EKUM3D

KWA Transaction ID : QP2063270306064714

Payment Status : Payment Successful

Packages	Amount
Special Package - pH,Turbidity,Conductivity,Total Hardness,Chloride,Iron,Nitrate,Total Coliform,E-coli	1590
Additional Fee	0
<b>Transaction Amount</b>	<b>1590</b>

Since the package details and rates changed from 01/02/2023 onwards, the details in the bill before 01/02/2023, the package amount may be different.

ഓൺലൈനായി അപേക്ഷിച്ചതിന് ശേഷം 15 ദിവസത്തിനകം തിരഞ്ഞെടുത്ത ലാബിൽ ജലസാമ്പിൾ സമർപ്പിക്കുന്നതിൽ അപേക്ഷകൻ പരാജയപ്പെട്ടാൽ, അപേക്ഷ നിരസിക്കപ്പെടും.ആ സാഹചര്യത്തിൽ റീഫണ്ട് ലഭ്യമല്ല.

Note: Application id ഉപയോഗിച്ച് 5 ദിവസത്തിനു ശേഷം പരിശോധന ഫലം ഡൗൺലോഡ് ചെയ്ത് എടുക്കാവുന്നതാണ് (qpay.kwa.kerala.gov.in).



**KERALA WATER AUTHORITY**  
**QUALITY CONTROL DISTRICT LAB KASARAGOD, VIDYANAGAR**  
**WATER ANALYSIS REPORT**

email : qclabkasaragod@gmail.com

Report No - KWA/QA/R/03/111/J/75/167				07/03/2025	
Customer Name and Address		1. Date of receipt		06-03-2025	
<b>HOLY FAMILY CONVENT PUBLIC SCHOOL BADIADKA PERDALA P.O KASARAGOD DT 671551 Phone : 9496293239 (NON DOMESTIC)</b>		2. Sample Provided by		Customer ( QUA_206327 )	
		3. Sample Code		42/25 (15)	
		4. Source of Sample		Bore well	
		5. Sample quantity and Condition		: 2 liter and Good	
		6. Test performing dates			
		From: 06/03/2025		To :07/03/2025	
SI No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Electrical Conductivity at 25°C	(micro mhos/cm)	IS 3025 (Part 14) : 2013 (Reaffirmed 2023)		25.76
2	Acidity	(mg/litre)	IS 3025 (Part 22) : 2024		--
3	Sulphate (asSO <sub>4</sub> )	(mg/litre)	IS 3025 (Part 24/Sec 1) : 2022	200	--
4	Fluoride (as F)	(mg/litre)	APHA 24 <sup>th</sup> Edition 4500-F-D SPADNS Method	1	--
5	Iron (as Fe)	(mg/litre)	IS 3025 (part 53) : 2004	1	BDL
6	Nitrate (as NO <sub>3</sub> )	(mg/litre)	APHA 24 <sup>th</sup> Edition 4500 NO <sub>3</sub> - B (UV Screening method)	45	BDL
7	Residual Chlorine	(mg/litre)	IS 3025 (Part 26) : 2021	0.2	--

**Remarks:**

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory.

BDL.-Below Detection Limit

Authorised By

Quality Manager  
Quality Control District Lab  
Kerala Water Authority  
Vidyanagar, Kasaragod - 671123

\* End Of Report\*

KWA/QC/DL/KSD/R/17

Issue No: 03

Issue Date : 25.02.2023

Rev No: 004

Rev Date:  
17.02.2025



**KERALA WATER AUTHORITY**  
**QUALITY CONTROL DISTRICT LAB KASARAGOD, VIDYANAGAR**  
**WATER ANALYSIS REPORT**

Tele phone No : 04994 255791  
email : qclabkasaragod@gmail.com

Report No - KWA/QA/R/03/111/J/75/167	07/03/2025
Customer Name and Address	1. Date of receipt
<b>HOLY FAMILY CONVENT</b>	06-03-2025
<b>PUBLIC SCHOOL</b>	2. Sample Provided by
<b>BADIADKA PERDALA P.O</b>	Customer ( QUA 206327 )
<b>KASARAGOD DT 671551</b>	3. Sample Code
<b>Phone : 9496293239</b>	42/25 (15)
<b>(NON DOMESTIC)</b>	4. Source of Sample
	Bore well
	5. Sample
	Drinking Water
	6. Sample quantity and Condition
	: 2 liter and Good
	7. Test performing dates
	From: 06/03/2025 To :07/03/2025

	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Colour	CU	IS 3025 (Part 4) : 2021	5	--
2	Odour		IS 3025 (Part 5) : 2018	Agreeable	--
3	Taste		IS 3025 (Part 8) : 2023	Agreeable	--
4	Turbidity	(NTU)	IS 3025 (Part 10) : 2023	1	<0.5
5	pH (25°C)		IS 3025 (Part 11) : 2022 (ISO 10523:2008)	6.5 to 8.5	7.83
6	Total Alkalinity (as CaCO <sub>3</sub> )	(mg/litre)	IS 3025 (Part 23) : 2023	200	--
7	Total Dissolved Solids (TDS 180°C)	(mg/litre)	IS 3025 (Part 16) : 2023	500	--
8	Total Hardness (as CaCO <sub>3</sub> )	(mg/litre)	IS 3025 (Part 21) : 2009 (Reaffirmed 2023)	200	9.90
9	Calcium (as Ca)	(mg/litre)	IS 3025 (Part 40) : 2024	75	--
10	Magnesium (as Mg)	(mg/litre)	IS 3025 (Part 46) : 2023	30	--
11	Chloride (as Cl)	(mg/litre)	IS 3025 (Part 32) : 1988 (Reaffirmed 2019)	250	1.94

**Remarks :**

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory.

BDL-Below Detection Limit

**Authorised By**  
**Quality Manager**  
**Quality Control District Lab**  
**Kerala Water Authority**  
**Vidyanagar, Kasaragod**

\* End Of Report\*

KWA/QC/DL/KSD/R/17

Issue No: 02

Issue Date : 06.05.2022

Rev No: 003

Rev Date:

17.02.2025

Page 1 of 1





**KERALA WATER AUTHORITY**  
**QUALITY CONTROL DISTRICT LAB KASARAGOD, VIDYANAGAR**  
**WATER ANALYSIS REPORT**

Tele phone No : 04994 255791

email : qclabkasaragod@gmail.com

Report No - KWA/QA/R/03/111/J/19/136a		08/03/2025			
Customer Name and Address		1. Date of receipt	06-03-2025		
<b>HOLY FAMILY CONVENT PUBLIC SCHOOL BADIADKA PERDALA P.O KASARAGOD DT 671551 Phone : 9496293239 (NON DOMESTIC) -</b>		2. Sample Provided by	Customer ( QUA_206327 )		
		3. Sample Code	42/25 (15)		
		4. Source of Sample	Bore well		
		5. Sample quantity	: 250ml		
		6. Test performing dates			
		From: 06/03/2025	To : 08/03/2025		
Sl No	Characteristics	3. Sample Code	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Total Coliforms	CFU /100 ml	IS 15185 : 2016; ISO 9308 - 1: 2014 Reaffirmed Year : 2021	Shall not be detectable in any 100 ml Sample.	Absent
2	<i>E.coli</i>	CFU /100 ml	IS 15185 : 2016; ISO 9308 - 1: 2014 Reaffirmed Year : 2021	Shall not be detectable in any 100 ml Sample.	Absent

Remarks:

The results reported relate only to the Sample received and tested. This test report shall not be reproduced except in full without the written approval of the laboratory.

  
Authorised by

Quality Manager  
Quality Control District Lab  
Kerala Water Authority  
Vidyanagar, Kasaragod - 671123

\* End Of Report\*

KWA/QC/DL/KSD/R/17

Issue No: 02

Issue Date : 06.05.2022

Rev No: 002      Rev Date: 04.01.2025

Page 1 of 1