

**DISTRICT FOOD TESTING LABORATORY, PATHANAMTHITTA
MARKET ROAD, OPPO; POLICE STATION, PATHANAMTHITTA
REPORT ON ANALYSIS OF WATER**

To,
Principal
Infant Jesus Central School
Thuvayoor
Kadambanadu

WA(P) 598 /2023		
SOURCE OF SAMPLE	Well water	
DATE OF RECEIPT	14.06.2023	
CHARACTERISTICS		REQUIREMENTS
COLOUR AND APPEARANCE	Agreeable	Not more than 2 Hazen units/true colour units
ODOUR	Agreeable	Agreeable
TASTE	Agreeable	Agreeable
TURBIDITY	2.5 NTU	Not more than 5.0 NTU
TOTAL DISSOLVED SALTS	31.6 ppm	Not more than 500.0 ppm
pH	7.05	6.5 to 8.5
ELECTRICAL CONDUCTIVITY	59.9 mho	-----
ALKALINITY	36.0 ppm	Not more than 200.0 ppm
CHLORIDES	38.0 ppm	Not more than 250.0 ppm
NITRATES	Nil	Not more than 45.0 ppm
SULPHATES	Nil	Not more than 200.0 ppm
AMMONIA FREE SALINE	Nil	Not more than 0.5 ppm
HARDNESS-TOTAL	26.0 ppm	Not more than 200.0 ppm
IRON	0.1 ppm	Not more than 0.3 ppm
BACTERIOLOGICAL ANALYSIS	110 mpn/100 ml	< 2 mpn/100 ml

REMARKS : 4000 ലിറ്റർ വെള്ളത്തിന് 10 ഗ്രാം ബ്ലീച്ചിംഗ് പൗഡർ കലർത്തുക.

Pathanamthitta

17.06.2023



[Signature]
RESEARCH OFFICER
Research Officer
District Food Testing Laboratory
Pathanamthitta

Note: The test report relates to the tested parameters of the given sample only
Reports shall not be reproduced except in full or part without approval of the laboratory



[Signature]
PRINCIPAL
Infant Jesus Central School
Thuvayoor, Kadambanad. P. O
Pathanamthitta, Kerala- 691 552

[Signature]
SECRETARY

Infant Jesus Central School
Thuvayoor, Kadambanad. P.O.
Pathanamthitta, Kerala 691 552

Annexure C


Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 139/2023

Dated: 20.6.2023

It is certified that an inspection team headed by ANIL G., Health Inspector
(Name of Officers with designation) from Primary Health Centre, Kadampnad
(Name of Department/ Office) inspected the Infant Jesus Central School, Thuvayoor
(Name & Address of the school) on 20.6.2023 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.
The above is valid for a period of One Year.

Signature with Seal: 

Name : ANIL G.

Designation : Health Inspector

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

To

Principal
Infant Jesus Central School, Thuvayoor

(Name & Address of the Institution)



* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

H. J. Kottapuram
PRINCIPAL
Infant Jesus Central School
Thuvayoor, Kadampnad. P. O
Pathanamthitta, Kerala- 691 552

Jebrin
SECRETARY
Infant Jesus Central School
Thuvayoor, Kadampnad. P. O
Pathanamthitta, Kerala- 691 552

Annexure C


Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated: 20.6.2023

No. 139/2023

It is certified that an inspection team headed by Anil G. Health Inspector
(Name of Officers with designation) from Primary Health Centre, Kadampnanad
(Name of Department/ Office) inspected the Infant Jesus Central School, Thuvayoor
(Name & Address of the school) on 20.6.2023 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. The above is valid for a period of One Year.

Signature with Seal: 

Name : Anil G.

Designation : Health Inspector
HEALTH INSPECTOR
PHC, KADAMPANAD
Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :



To


Principal
Infant Jesus Central School, Thuvayoor

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

58 | Page




PRINCIPAL
Infant Jesus Central School
Thuvayoor, Kadampnanad. P. O
Pathanamthitta, Kerala-691 552


SCHOOL SECRETARY
Infant Jesus Central School
Thuvayoor, Kadampnanad P.O.,
Pathanamthitta, Kerala 691 552