

Annexure ARevised Checklist for School FitnessSchool Name: Joe Mount Public SchoolSchool Code : 76203School Type (Govt./Aided/Unaided): Unaided

Sl.No.	Item to be verified	Yes	No	Remarks
1.	Building Structurally stable	☒	☐	
2.	Existing compound walls safe and intact	☒	☐	
3.	Premises free of unsafe pits, mounds and slopes.	☒	☐	
4.	Whether the new Constructions comply with Building Rules & approvals	☒	☐	
5.	Dangerous/ overgrown trees and branches pruned or removed	☒	☐	
6.	Kitchen does not have any safety issue	☐	☐	NA
7.	Whether Asbestos/Tin/ Aluminium sheet roofs have been replaced?	☒	☐	
8.	Whether Parapet Walls are there for for wells and open wells are covered ?	☒	☐	
9.	Electrical wiring safe (old/damaged wiring replaced)	☒	☐	

10. Transformers (if nearby) fenced properly ☐ ☐
11. No exposed or hazardous electric posts/ electric wires near school. ☐ ☐
12. Fire extinguisher installed ☐ ☐

The inspecting officer may offer remarks regarding item 10 and 11. The head of institution shall rectify the defects and obtain NOC from KSEB in cases pertaining to Items 10 and 11.

HEALTH AND SANITATION

13. Adequate, clean, ventilated toilets with running water ☒ ☐
14. Classrooms, common areas and kitchen are clean ☒ ☐
15. First aid kit available ☒ ☐
16. Overgrown vegetation/garbage removed from School premises ☒ ☐
17. Rodent control measures are in place ☒ ☐

Items 13 to 17 are to be certified by the Health staff (HI/HS) of the concerned Local Body.

Signature & Seal of School Principal/HM:

Signature & Seal of Health inspector :

Signature & Seal of Assistant Engineer, LSGD:

Inspection Date: 23.6.26

T. Alugapathy
Principal
Joe Mount Public School
Chunangamvely
Erumathala, P. O.
Aluva - 683 112

HEALTH INSPECTOR
FAMILY HEALTH CENTRE
Edathala



Report ID: ECO/22/06/3053	Report Date: 22/06/2026	Page 1 of 1
---------------------------	-------------------------	-------------

Customer Name & Address	JOE MOUNT PUBLIC SCHOOL CHUNGAMVELY, ALUVA		
Sample Name:	Water	Sample Received on	18/06/2026
Sample ID	EA/26/06/3053	Test started on:	18/06/2026
Sample Description:	Filter Out	Test completed on:	22/06/2026
Sample Condition:	Good	Sample Drawn by	Customer
Sample quantity:	1 L	Received Temperature	Ambient

Sl No	Parameters	Test method	Unit	Result	Limit As per IS 10500
1	Colour	APHA 2120 B	Hz	1.00	Max 5
2	Odour	IS:3025 PART 6	----	Agreeable	Agreeable
3	pH	APHA 4500 H ⁺ B	----	6.52	6.5-8.5
4	Total Dissolved Solids	APHA 2540 C	mg/L	78.0	Max 500
5	Turbidity	APHA 2130 B	NTU	<1.00	Max 1.00
6	Total Hardness as CaCO ₃	APHA 2340 C	mg/L	24.0	Max 200
7	Calcium as Ca	APHA 3500 B	mg/L	8.01	Max 75
8	Magnesium	APHA 3500 B	mg/L	0.97	Max 30
9	Chloride	APHA 4500 Cl B	mg/L	18.0	Max 250
10	Iron	APHA 3500 Fe B	mg/L	<0.10	Max 0.3
11	Total Alkalinity as CaCO ₃	APHA 2320 B	mg/L	36.0	Max 200
12	Sulphate as SO ₄	APHA 4500 SO ₄ E	mg/L	4.00	Max 200
13	Total coliform bacteria	IS 15185:2016	cfu/100ml	<1*	Absent/100ml
14	<i>E. coli</i>	IS 15185:2016	cfu/100ml	<1*	Absent/100ml

<1* is equivalent to Absent or non-detectable.

Remarks: The sample given complies with all the above test parameters as per IS10500.

SAHALA NASRIN	LAKSHMI RAJEEV	ANITHA KHADER
Chemist	Microbiologist	Lab Head
Checked by	Checked by	Authorised by

Notes

- The test result is pertained to the sample submitted only.
- The sample will be retained for 15 days in chilled condition.
- The test report shall not be produced except in full without the written permission of the lab.

*END OF REPORT