


PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.

No. 002/2022-23



It is certified that an inspection team headed by HEALTH INSPECTOR  
SYJ. S. S. RADHAKRISHNAN JHI RANHA R JHI (Name of Officers  
with designation) from FAMILY HEALTH CENTRE - NALLUKETTU (Name of  
Department/Office) inspected the LITTLE FLOWER PUBLIC SCHOOL  
MURINGOOR P.O, CHALAKUDY, 680309 (Name & Address of  
the School) on 10/10/2022 and found that the LITTLE FLOWER PUBLIC  
SCHOOL, MURINGOOR (Name of school) has safe  
drinking water facilities for the students and members of staff of the institution and is maintaining  
the hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State/U.T. Govt.

The above valid for a period of 1 YEAR (9-10-2023)

Signature with Seal : [Signature]

Name : S.S.S. K.S.

Designation : Health Inspector.

To

THE PRINCIPAL

LITTLE FLOWER PUBLIC SCHOOL

MURINGOOR P.O, CHALAKUDY 680309

(Name & Address of the Institution)

HEALTH INSPECTOR  
NALLUKETTU P.H.C.  
KORATTY G.P.  
THRISSUR-680308.



4

[Signature]  
Sr. Soja Joseph  
Principal  
Little Flower Public School  
Muringoor - 680309  
littlefps@gmail.com  
School Code : 75395

## TEST REPORT

Test Report No : CKL/22/T1288

Date : 17-09-2022

- Name of Customer : LF Public School
- Customer Address : Muringoor
- Test Requisition No. & Date : LWF538 & 13-09-2022
- Date of Sample Received : 13-09-2022
- Sample Analysis Date : 16-09-2022 To 17-09-2022
- Sample Name : Well Water
- Sample ID : T1288
- Quantity of Sample Received : 1 L
- Sample Drawn by : The Medical Officer, PHC Nalukettu
- Sample Condition : Received in plastic bottle

Parameters	Unit	Result	Specification	Detection Limit	Test Method
Alkalinity as CaCO <sub>3</sub>	mg/ L	10.45	Max- 200	-	IS: 3025 Part 23
Calcium	mg/ L	4.10	Max- 75	-	IS: 3025 part 40
Chloride	mg/ L	15.77	Max- 250	-	IS: 3025 part 32
Fluoride	mg/ L	Not Detected	Max- 1	-	IS: 3025 part 60
Hardness	mg/ L	16.40	Max- 200	-	IS: 3025 part 21
Iron as Fe	mg/ L	0.06	Max- 0.3	0.0005	CKL/ANL/WA-021
Nitrate as NO <sub>3</sub> <sup>-</sup>	mg/ L	2.64	Max- 45	0.5	IS: 3025 part 34
pH	-	6.53	6.5 – 8.5	-	IS: 3025 Part 11
Sulphate as SO <sub>4</sub> <sup>2-</sup>	mg/ L	BDL	Max- 200	4.0	IS: 3025 part 24
Total Dissolved Solids	mg/ L	64.0	Max- 500	-	IS: 3025 part 16
Turbidity	NTU	< 2	Max- 5	-	IS: 3025 part 10
Acidity	mg/ L	6.12	-	-	IS: 3025 Part 22

The sample complies as per IS: 10500- 2012, with respect to the tested parameters.

BDL-Below Detection Limit

Total Number of Determination: 12 only

*True copy*  
*Dr. hee rose*

**MANAGER**  
LITTLE FLOWER PUBLIC SCHOOL  
MURINGOOR - 680 316

*[Signature]*  
Authorized signatory

Lab Manager  
CARe Keralam Ltd

Note: The test results relate only to the sample tested. The report shall not be reproduced except in full, without the written approval of the laboratory  
Address: KINFRA Small Industries Park, Nalukettu road, Koratty-680309, Ph: 0480 2735837, Fax: 0480 2735737, E-mail: [lab@carekeralam.com](mailto:lab@carekeralam.com)

**TEST REPORT**

Test Report No : CKL/22/T1288

Date : 15-09-2022

- Name of Customer : LF Public School
- Customer Address : Muringoor
- Test Requisition No. & Date : LWF538 & 13-09-2022
- Date of Sample Received : 13-09-2022
- Sample Analysis Date : 13-09-2022 To 15-09-2022
- Sample Name : Well Water
- Sample ID : T1288
- Quantity of Sample Received : 250 ml
- Sample Drawn by : The Medical Officer, PHC Nalukettu
- Sample Condition : Received in sterile bottle

Parameters	Unit	Result	Test Method
Coliforms	MPN/ 100 ml	< 1.8	Standard Methods for the Examination of water & waste water, APHA - 23rd Edition 2017, Chap- 9221 B
<i>E.coli</i>	MPN/ 100 ml	< 1.8	Standard Methods for the Examination of water & waste water, APHA - 23rd Edition 2017, Chap- 9221 F
Fecal Coliforms	MPN/ 100 ml	< 1.8	Standard Methods for the Examination of water & waste water, APHA - 23rd Edition 2017, Chap- 9221 E

Note: '< 1.8' is equivalent to 'Absent' as per Test method  
Total Number of Determination: 3 only

*True copy  
In. hee Rose*



*Signature*

**MANAGER**

**LITTLE FLOWER PUBLIC SCHOOL  
MURINGOOR - 680309**

**Authorized signatory  
Sr. Soja Sijo Varghese T.  
(Microbiologist)**

Principal  
**Little Flower Public School  
Muringoor - 680309**  
lab@carekeralam.com

Note: The test results relate only to the sample tested. The report shall not be reproduced except in full, without the written approval of the laboratory

Address: KINFRA Small Industries Park, Nalukettu road, Koratty-680309, Ph: 0480 2735837, Fax: 0480 2735737, E-mail: lab@carekeralam.com

littlefps@gmail.com  
School Code : 75395

*Signature*