



ശുചിത്വ സർട്ടിഫിക്കറ്റ്

സർട്ടിഫിക്കറ്റ് നമ്പർ : 1/2022

തീയതി 06/06/2022

..... എന്ന് വ്യക്തിയുടെ ഉടമസ്ഥതയിൽ കെട്ടിടത്തിൽ നടത്തുന്ന

..... എന്ന സ്ഥാപനം പൊതുജനാരോഗ്യ നിയമപ്രകാരമുള്ള ആരോഗ്യ ശുചിത്വ വ്യവസ്ഥകൾ പാലിക്കുന്നതായി സാക്ഷ്യപ്പെടുത്തുന്നു. ടി വ്യക്തി വിഴ്ച വരുത്തുന്ന പക്ഷം യാതൊരു മുന്നറിയിപ്പും കൂടാതെ സർട്ടിഫിക്കറ്റ് റദ്ദുചെയ്യുന്നത് ഉൾപ്പെടെയുള്ള നിയമ നടപടികൾ സ്വീകരിക്കുന്നതാണ്.

പരിശോധന നടത്തിയ തീയതി : 6/6/2022

സർട്ടിഫിക്കറ്റ് നൽകുന്ന തീയതി : 6/6/2022

സർട്ടിഫിക്കറ്റ് കാലാവധി : 03ന മാസം (2022-2023 മാർച്ച്)

സ്ഥാപനങ്ങൾ പാലിക്കേണ്ട ആരോഗ്യ ശുചിത്വ വ്യവസ്ഥകൾ

1. കേടായ പാനീയങ്ങൾ ശുചിയായി കൈകാര്യം ചെയ്യുക. ക്ഷേത്രോദ്യമല്ലാത്ത സാധനങ്ങൾ വില്ക്കരുത്.
2. പുറകിലെ ഉല്പന്നങ്ങൾ, പാൻപരാൾ എന്നിവ വിൽക്കരുത്.
3. സ്ഥാപനവും പരിസരവും ശുചിത്വം പാലിക്കുക.
4. ജൈവ അജൈവ പ്ലാസ്റ്റിക് മാലിന്യങ്ങൾ വലിച്ചെറിയരുത്. അവ സ്വന്തമായി നശിപ്പിക്കാനുള്ള സൗകര്യം ചെയ്യുക.
5. ദ്രവമാലിന്യങ്ങൾ പൊതുകനാലിലേക്ക് ഒഴുക്കി വിടരുത്.
6. കേടായ പദാർത്ഥങ്ങൾ കൈകാര്യം ചെയ്യുന്ന തൊഴിലാളികൾ ശുചിത്വം പാലിക്കുക. സർക്കാർ മെഡിക്കൽ ഫിറ്റ്നസ് സർട്ടിഫിക്കറ്റ് ഉണ്ടായിരിക്കേണ്ടതാണ്.
7. പാക്ക് ചെയ്ത ആഹാര പദാർത്ഥങ്ങളിൽ നിയമപ്രകാരമുള്ള ലേബൽ പതിക്കുക.
8. തൊഴിലാളികൾക്ക് ആവശ്യമായ അടിസ്ഥാന സൗകര്യങ്ങൾ ഉണ്ടായിരിക്കേണ്ടതാണ് (വിശ്രമ മുറി, ടോയ്ലെറ്റ്)
9. ഉപഭോക്താക്കൾക്ക് ആവശ്യമായ അടിസ്ഥാന സൗകര്യം (ടോയ്ലെറ്റ്)

സ്ഥലം : Nillanjal
തീയതി : 06/06/2022



PRINCIPAL
M.E.S PUBLIC SCHOOL
PANOOR

ഹെൽത്ത് ഉദ്യോഗസ്ഥൻ
06/06/2022



GEO WATER CLINIC

Water Quality Testing Laboratory, Noon Enterprises Building, Main Road, Thalassery
Pincode: 670101, Ph: 0490-2323131, Mobile: 9400326111
Email: geowaterclinic@gmail.com
(Approved by Kerala State Pollution Control Board)



ANALYSIS REPORT OF WATER SAMPLE

Report No: 2205010557

Customer Name : PRINCIPAL ..
Customer Address : M.E.S PUBLIC SCHOOL, PANOOR, KAMELKKAL, P.O PUTHOOR
Customer Contact Number : 9496239440

Sample Type	Source	Sample Container	Sample Condition	Test Method	Date and Time of Sample Collection	Date and Time of Sample Receipt	Test Date
DINKING WATER	BORE WELL	PLASTIC BOTTLE	GOOD	APHA	2022-05-10 11:46 AM [JHI ANITHA M.P]	10-05-2022	16-05-2022

S.L NO.	PARAMETER	UNIT	TEST RESULT	DESIRABLE LIMIT As Per.....
	pH @ 25°C		6.2	6.5-8.5
	Conductivity @ 25°C	µs/cm	149	
	Turbidity	NTU	21.0	5.0
	Total Dissolved Solids	mg/L	102	500
	Total Alkalinity	mg/L	68	200
	Chloride	mg/L	20	250
	Ammonia as Nitrogen	mg/L	5.2	0.5
	Total Hardness	mg/L	64	200
	Calcium Hardness	mg/L	36	
	Magnesium Hardness	mg/L	28	
	Calcium	mg/L	14.4	75
	Magnesium	mg/L	6.8	30
	Iron	mg/L	1.4	0.3
	Total Coliform Bacteria	MPN/100ml	23	
	Fecal coliform Bacteria	MPN/100 ml	NL	

REMARKS: pH is low ,ammonia, iron are high and coliform bacteria present in the sample.

PRINCIPAL
M.E.S PUBLIC SCHOOL
PANOOR



GEO WATER CLINIC

Water Quality Testing Laboratory, Noon Enterprises Building, Main Road, Thatassery
Pincode: 670101, Ph: 0490-2323131, Mobile: 9400326111
Email: geowaterclinic@gmail.com
(Approved by Kerala State Pollution Control Board)



ANALYSIS REPORT OF WATER SAMPLE

Test Report No: 2205125952

Customer Name : PRINCIPAL
Customer Address: M.E.S PUBLIC SCHOOL, PANOOR, KAMELIKKAL, P.O PUTHOOR
Customer Contact Number : 9496238440

Sample Type	Source	Sample Container	Sample Condition	Test Method	Date and Time of Sample Collection	Date and Time of Sample Receipt	Test Date
DRINKING WATER	OPEN WELL	PLASTIC BOTTLE	GOOD	APHA	2022-05-10 11:23 AM [JHITHANITHA M.P.]	10-05-2022	16-05-2022

SL NO.	PARAMETER	UNIT	TEST RESULT	DESIRABLE LIMIT As Per.....
1	pH @ 25°C		5.6	6.5-8.5
2	Conductivity @ 25°C	µs/cm	57	
3	Turbidity	NTU	0.4	5.0
4	Total Dissolved Solids	mg/L	54	500
5	Total Alkalinity	mg/L	20	200
6	Chloride	mg/L	20	250
7	Ammonia as Nitrogen	mg/L	Below Detection Level	0.5
8	Total Hardness	mg/L	20	200
9	Calcium Hardness	mg/L	12	
10	Magnesium Hardness	mg/L	8.0	
11	Calcium	mg/L	4.8	75
12	Magnesium	mg/L	1.9	30
13	Iron	mg/L	0.1	0.3
14	Total Coliform Bacteria	MPN/100ml	23	
15	Fecal coliform Bacteria	MPN/100 ml	NIL	

REMARKS: pH is low and coliform bacteria is present in the sample.

PRINCIPAL
M.E.S PUBLIC SCHOOL
PANOOR



Signature of Head of Laboratory: