



Office of Station Officer
Fire and rescue Station
Thiruvananthapuram

No. C. 625/2021

Date: 24.06.2021

FIRE FIGHTING SYSTEM INSPECTION REPORT

As per the request of The Manger Model Public School, Model Gardens Technocity, Pallipuram, Trivandrum, vide letter dated 21.06.2021, I have personally inspected the firefighting arrangements provided in the education buildings of Model Public School, Model Gardéns Technocity, Pallipuram, Trivandrum, Kerala, with survey number: 376/12,376/14, and found the following arrangements,

The following arrangements were found

1. Fire Extinguisher
2. Hose Reel
3. Down Comer
4. Booster Pump 900LPM
5. Fire Brigade inlet
6. Over Head Tank 10000 Ltr Capacity

The above arrangements were tested and found working satisfactory at the time of inspection.



Station Officer
Fire and rescue Station
Thiruvananthapuram

FIRE SAFETY CERTIFICATE

No. FRSKZM/405/2024-C

Dated: 06/06/2024

Certified that the Model Public School (name of the building or premises) at Model Gardens Technocity Pallipuram Trivandrum (address) comprised of basement(s) and Ground +1 (upper floors) owned/ occupied by Model Public School (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 06.06.2024 (date of inspection) in the presence of Manager (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes XII (X/ XII) With effect from 06.06.2024 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended:-

1. All the fire fighting Equipment should be kept in proper Working Condition
2. All the means of Exit should be kept clear
- 3.
- 4.

Issued on 06.06.2024 (date of issue) at Pallipuram (place) by

*Strike out whichever is not applicable.



Signature with Seal: [Signature]

Name

B. Rajesh Kumar
 റജേഷ് കുമാർ
 ഓടക്കുനാപാലിക്കൽ, കഴക്കൂട്ടം - 635 587
 Ph: 0471-2700029

Designation

Name & Address of Department/ Office: Fire And Rescue Station Kazhakkuttom.

To

Model Public School, Model Gardens Technocity Pallipuram

(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

(reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.