

NO OBJECTION CERTIFICATE FOR
SCHOOLS

KERALA STATE HEALTH SERVICES

KOTTAYAM DISTRICT

THIS IS TO CERTIFY THAT Nirmal Jayathi

Public School Palakadu SCHOOL HAD BEEN INSPECTED BY ME ON

11/05/2020 AND FOUND SATISFACTORY ACCORDING TO THE

PUBLIC HEALTH CONDITIONS/FACILITIES INITIATED BY THE

SCHOOL AUTHORITY.



PLACE :

DATE : 19/05/2020

SIGN OF HI/LPHO

HEALTH INSPECTOR
PHC MEENACHIL

MEDICAL OFFICER IN CHARGE
FHC Meenachil
Kizhapparayar P. O, Kottayam Dt.
Pin : 686 578



QUALITY CONTROL SUB DISTRICT LABORATORY

KERALA WATER AUTHORITY,
PALA, KOTTAYAM

Telephone No. 04822 200675, Email: qcsdlpala@gmail.com

(NABL Recognized Block level Government Drinking Water Testing Laboratory)

TEST REPORT

Certificate No. NABL- DWT -01037

Report No: PL 1389/PALA/05/2026	Date: 15.05.2026
---------------------------------	------------------

Customer Name & Address NIRMAL JYOTHI PUBLIC SCHOOL PALAKADU , MEENACHIL - 686577	1.Date of Receipt	12.05.2026
	2.Sampling done by	CUSTOMER
	3.Sample Code	2026/QCSDL/PALA/PL 1773
	4.Source of Sample	WELL
	5.Sample Quantity	2 LITRE
	6.Sample conditions	ACCEPTABLE
	7.Test performing dates	12.05.2026 TO 14.05.2026

Characteristics	Unit	Test Method	Acceptable limits as per IS 10500:2012	Limit of detection LOD	Result
Colour	HU	APHA 24 th Edition(2023) 2120 B – visual comparison method	5	1	NT
Odour		IS 3025 (part 5) :2018	Agreeable	Agreeable	NT
Taste		IS 3025 (Part 8) :2023	Agreeable	Agreeable	NT
Turbidity	(NTU)	IS 3025 (Part10):2023 Nephelometric Method	1	0.5	0.63
pH at 25 °C		IS 3025 (Part 11) – 2022 Potentiometric Method	6.5 - 8.5	2	6.50
Alkalinity	(mg/litre)	IS 3025 (Part 23) :2023 Indicator Method	200	5	NT
Total dissolved solids (TDS)	(mg/litre)	IS 3025 (Part 16 :2023 Gravimetric Method/TDS Meter)	500	5	NT
Total hardness (as CaCO ₃)	(mg/litre)	IS 3025 (Part21) - 2009 (Reaffirmed 2023) - EDTA Method	200	5	30
Calcium (as Ca)	(mg/litre)	IS 3025 (Part 40) :2024 EDTA Titrimetric Method	75	5	NT
Magnesium (as Mg)	(mg/litre)	APHA 24 th Edition (2023) 3500 – Mg B Calculation Method	30	5	NT
Chloride (as Cl)	(mg/litre)	IS 3025 (Part32) -1988 (Reaffirmed 2019) Argentometric Method	250	5	9.89

Remarks:-

NB:- The result stated above related only to the sample(s)submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the laboratory


*Samples will be retained only for 7 days after completion of analysis

*Sampling is not done by the Lab

*BDL – Below Detection Limit

*NT- Not Tested

End of the Report



Reviewed and Authorized by
(Signature with Name)

Sandhya
SANDHYA



QUALITY CONTROL SUB DISTRICT LABORATORY

KERALA WATER AUTHORITY,

PALA, KOTTAYAM

Telephone No. 04822 200675, Email: qcsdlpala@gmail.com

TEST REPORT

Report No :PL1541/PALA/05/2026

Date:25.05.2026

CUSTOMER NAME & ADDRESS NIRMAL JYOTHI PUBLIC SCHOOL MEENACHIL PO PALAKADU - 686577	1.Date of Receipt	22.05.2026
	2.Sampling done by	CUSTOMER
	3.Sample Code	2026/QCSDL/PALA/PL 1928
	4.Source of Sample	WELL
	5.Sample Quantity	100 ML
	6.Sample conditions	ACCEPTABLE
	7.Test performing dates:	22.05.2026 TO 23.05.2026

BACTERIOLOGICAL ANALYSIS

Sl No.	Parameters	Acceptable limits as per – IS 10500:2012	Test Method	Result
1	Coliforms	Shall not be detected/100ml	IS 15185:2016 (Reaffirmed 2021)	ABSENT
2	E.coli	Shall not be detected/100ml	IS 15185:2016 (Reaffirmed 2021)	ABSENT

Test method

Coliforms: Membrane Filtration Method

E. coli: Membrane Filtration Method

Remarks-

NB:- The result stated above related only to the sample(s)submitted for testing. This test Certificate shall not be reproduced except in full without the written approval of the laboratory

*Samples will be retained only for 7 days after completion of analysis

*Sampling is not done by the Lab

END OF REPORT



Authorized By

Bini

(Bacteriologist)

BINIMOL ABRAHAM

Page 1-1

Rev. Date: 27.03.2025

KWA/QC/PALA/AR/F4

Issue No.01

Rev. No 01