



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY

KIZHAKKUMPATTUKARA, THRISSUR

Telephone No - 0487-2338380, E-mail -kwa.qc.tsr@gmail.com

Test Report

Test Report. No : KWA/QCDL/TSR/2531/2025

Report Date : 27/03/2025

Customer Name & Address			1. Date of Receipt :25/03/2025	
Notre Dame School, Vettikuzhy, Chaippankuzhy, Mob: 6238154068			2. Sampling done by : The Customer	
			3. UID No. of Sample: KWA/QCDL/TSR/S-002531/2025	
			4. Source of Sample : Borewell	
			5. Sample condition : Good	
			6. Name of sample : Water	
			7. Purpose of test : Commercial	
			8. Sample Quantity :100ml	
			9. Test Performing Dates	
			From :25/03/2025	To : 27/03/2025
Sl. No.	Parameters	Test Method	Acceptable limits as per-IS 10500-2012	Result
1	Total Coliforms	IS 15185 : 2016 ISO 9308 - I : 2014	Shall not be detected / 100ml	Not detected
2	E.coli	IS 15185 : 2016 ISO 9308 - I : 2014	Shall not be detected/ 100ml	Not detected

Remarks:- Coliform & E.coli Bacteria not Detected

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

See
Reviewed by: Sruthy P S
(Microbiologist)



219
Authorized By: Jiji K S
(Microbiologist)

Deputy Quality Manager
Quality Control District Laboratory
Kerala Water Authority
Thrissur-680 005

*** End of Report ***

KWA/QCDL/TSR-R-No:6	Issue No:2	Issue Date 10/01/2023
Rev.No: 00	Rev Date: 00	Page 1 of 1