



Telephone::0485-2998170  
email:-qcsdlmvpa@gmail.com

**KERALA WATER AUTHORITY**  
**QUALITY CONTROL SUB DISTRICT LAB, MUVATTUPUZHA-686673**  
**WATER TEST-BACTERIOLOGY REPORT**

Report No: KWA/QCSDL-MVPA/1113/07/25

Report Issue Date: 10.07.2025

<b>CUSTOMER NAME &amp; ADDRESS</b>  RIGHT PATH GLOBAL SCHOOL PEZHAKKAPILLY MUVATTUPUZHA	Date of Receipt of Payment	07.07.25		
	Date of Sample received	07.07.25		
	Sample given by	Medical Officer FHC Paipra		
	Sample Code	MVPA/1113/07/25		
	Sample Name	DRINKING WATER		
	Sample Condition	Good		
	Source of Sample	KWA TAP		
	Sample Quantity	200 ml		
Test performing date: From :07/07/2025 To 08/07/2025				
<b>Sl. No.</b>	<b>Parameter</b>	<b>Acceptable Limit as per IS 10500-2012</b>	<b>Test Method</b>	<b>Result</b>
1	Total Coliform	Shall not be Detected/100ml	IS15185-2016	ABSENT
2	E-Coli	Shall not be Detected/100ml	IS15185-2016	ABSENT

Remarks:-

- NB:-1) The result stated above related only to the sample(s) submitted for testing by the Customer.  
2) The samples retain for 15 days from the end date of analysis  
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

End of Report



Reviewed & Authorized By

C V SREELAKSHMI

KWA/QCSDL/MVPA/F-26	Issue Date : 02.07.2021
RevNo:04	Rev,Date :-10.08.2023

Mrs Sabeela Anoo  
Principal  
Right Path Global School  
Nirap Road, RPGS Jn  
Pezhakkapilly P.O  
Muvattupuzha,

MANAGER  
RIGHT PATH GLOBAL SCHOOL  
MUVATTUPUZHA