

PH: 0475 2221151

E-mail - jicameenadplr@gmail.com



**QUALITY CONTROL SUB DISTRICT LABORATORY**  
**KERALA WATER AUTHORITY**  
**JICA WTP MEENAD THOLICODU.P.O, PUNALUR KOLLAM - 691333**  
**REPORT ON ANALYSIS OF WATER**

Report No - 2026/QCSDL/JICA/600.		Date:- 20.05.2026.		
Customer Name & Address		1. Date of Receipt :18.05.2026.		
<b>SABARI GIRI CENTRAL SCHOOL.</b> <b>ANCHAL P O</b> <b>Pin:- 691306.</b> <b>PH:-8848368089.</b>		2. Sampling done by:-Health Inspector CHC Anchal.		
		3. Sample Code : 2026/QCSDL/JICA/600.		
		4. Source of sample: Open Well Water.		
		5. Sample Description : Drinking Water		
		6. Sample Quantity : 250 ml.		
		7. Sample Condition : Good.		
		8. Test Performing Dates		
				From : 18.05.2026      To :20.05.2026
Sl. No.	Parameters	Acceptable limits as per IS 10500 - 2012	Test Method	Result
1	Total Coliforms/ 100 ml	Shall not be detected/100 ml	IS 15185 : 2016 (Reaffirmed 2021)	ABSENT
2	<i>E. coli</i> /100 ml	Shall not be detected/100 ml	IS 15185 : 2016 (Reaffirmed 2021)	ABSENT

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

* End of Report *	Authorized By  Bacteriologist
-------------------	-------------------------------------

**BACTERIOLOGIST**  
QUALITY CONTROL SUB DISTRICT LAB  
JICA WTP MEENAD  
KERALA WATER AUTHORITY  
PUNALUR