

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated: 29/05/2026

Pawan Kumar / Amit Kumar

(Name of Officers with designation) from.....11: P. Jal Nigam.....PHED

This certificate is valid till **01 Year (31/05/2027)**

Name: ... PAWAN KUMAR ...

Name & Address of the Office / Department: **U.P. Jal Nigam (Rural)**
Auraiya, Uttar Pradesh

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Office of Executive Engineer, Khand Karyalay
Up Jal Nigam (Rural), Mihauli, Auraiya



Test Report Water

URL No.	TC.1382025000000125f	Report No.	125	Date	29.05.2026	Page No.	125
Customer Details							
Office Name & Address		ST. FRANCIS ACADEMY, Anepur, Kharka P.O. Auraiya.					
Ref. Letter No. & Date		27.05.2026					
Basic Details of Sample							
District	AURAIYA			Block	Auraiya		
Gram Panchayat	Anepur			Village	Anepur		
Habitation	Anepur			Location	Anepur		
Water Source	RO Water			Sample No	AUR27//05/11		
Quantity of Sample	1000ML			Date of S.C	27.05.2026		
Receiving Date	27.05.2026			S. Collector	Mr. Mahendra Singh		
Sample Depositor	Mr. Mahendra Singh			Analysis Completion Date -			
Analysis Start Date	27.05.2026			29.05.2026			
Sampling Method	IS 17614 (Part 1) : 2021			Environmental Condition			
Temperature	25±3°C			Humidity 50±15%			
Technical Data of Analysis							
S. No.	Analyzed Parameters	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis		
			Acceptable Limit	Permissible			
1	Taste	Agreeable	Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS 3025 (Part 8): 1984		
2	Odour	Agreeable	Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS 3025 (Part 5): 2018		
3	Colour	10	5	15	IS 3025 (Part 4): 1983 (Platinum Cobalt Visual Comparison Method)		
4	Turbidity (NTU)	1.11	1	5	IS 3025 (Part 10): 2023 (Nephelometric method)		
5	PH	8.03	6.5	8.5	IS 3025 (Part 11): 2022 (Electrometric Method)		
6	TDS (Mg/L)	92	500	2000	IS 3025 (Part 16): 2023 Gravimetric Method		
7	Alkalinity (Mg/L)	48	200	600	IS 3025 (Part 23): 2023 (Titration Method)		
8	Total Hardness (Mg/L)	38	200	600	IS 3025 (Part 21): 2019 (Titration Method)		
09	Chloride Mg/L	20	250	1000	IS 3025 (Part 32): 1988 (Titration Method)		
10	Calcium (as Mg), Mg/l	32	75	200	IS 3025 (Part 40): 2019		
11	Magnesium (as Mg), Mg/l	1.458	30	100	IS 3025 (Part 46): 2023		
*These Parameters are out of NABL Scope, BDL- Below Detection Limit, NT- Not Tested							
Note	1- This Certificate refers only to the particular sample (s) submitted for testing. 2- This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory 3- The test result reported in this certificate are valid at the time of and under the stated conditions of measurements. 4- Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified. 5- Parameters above permissible limit are written in Bold. 6- Source is not verified by the Laboratory.						
Prepared by Atul Kumar Deputy Quality/Technical Manager	District Level Water Analysis Laboratory Auraiya Mob. 9820000000						

END OF THE REPORT