



KERALA WATER AUTHORITY

Telephone:0484-2623576
email:-qcdlaluva@gmail.com



TC-12119

QUALITY CONTROL DISTRICT LAB,ALUVA -683101

WATER TEST REPORT

ULR NO:TC955224000030378F

Report Issue Date: 23.08.2024

Customer Name & Address St Joseph Public School Manalimukku NAD P O	Date of Receipt of Payment	07.08.24
	Date of Sample received	14.08.24
	Sample given by	MO I/C , FHC Edathala
	Sample Code	ALY/S/18502/8/24
	Sample Name	Drinking Water
	Sample Condition	Good
	Source of Sample	Well
	Sample Quantity	2 Litre
	Test performing dates :	From : 17.08.24 to 19.08.24

SL.N	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Turbidity	NTU	IS 3025 (Part10)-2023	1.0	0.29
2	pH at 25°C	-	IS 3025 (Part 11)-2022	6.5 to 8.5	7.38
3	Total Hardness (as CaCO3)	mg/L	IS 3025 (Part21)-2009(Reaffirmed 2019)	200	52.52
4	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	10.78
5	Iron (as Fe)	mg/L	IS 3025 (Part 53)-2003 (Reaffirmed 2019)	1	BDL
6	Nitrate (as NO3)	mg/L	APHA 23rd Edition(UV Screening Method) 2017	45	14.72
7	Electrical conductivity at 25° C	micromhos/cm	IS 3025 (Part 14)-2013(Reaffirmed 2019)	-	151

Remarks:- DL : Detectable Limit
BDL : Below Detectable Limit


- NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .
2) The samples retain for 15 days from the end date of analysis
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

For 59
Authorized by

CHEMIST
Quality Control District Lab
Kerala Water Authority
Aluva

End of Report

KWA/QCDL/ALY/01-2020	Issue Date : 04.10.2020
Rev No: 02	Rev.Date : 30/07/2023
Page 1 of 1	





Telephone:0484-2623576
email:-qcdlaluva@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB,ALUVA -683101
WATER TEST-BACTERIOLOGY REPORT


Report No: ALY/B/5594

Report Issue Date: 23.08.2024

Customer Name & Address St Joseph Public School Manalimukku NAD P O		Date of Receipt of Payment	07.08.24	
		Date of Sample received	14.08.24	
		Sample given by	MO I/C , FHC Edathala	
		Sample Code	ALY/B/5594	
		Sample Name	Drinking Water	
		Sample Condition	Good	
		Source of Sample	Well	
		Sample Quantity	200ml	
		Test performing dates :	From : 16.08.24 to 17.08.24	
Sl. No.	Parameter	Acceptable Limit as per IS 10500-2012	Test Method	Result
1	Total Coliform	Shall not be Detected/100ml	IS15185-2016	Absent
2	E-Coli	Shall not be Detected/100ml	IS15185-2016	Absent

NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .
2) The samples retain for 15 days from the end date of analysis
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Authorized By


Aysha Sainudeen

End of Report

KWA/QCDL/ALY/01-2020		Issue Date : 04.10.2020	
Rev No: 01	Rev,Date : 02/06/2021	Page 1 of 1	

