

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 129

Date : 16.09.2026

It is certified that an inspection team headed by DR. RAHUL MISHRA
Prabhaxi Chikitsa Adhikari (MOL Kannaui) (Name of Officers
with designation) from Health Department CHC, Chhibramau (Name of
Department/Office) inspected the ST. PAUL'S SCHOOL, LALAKPUR
CHHIBRAMAU, KANNAUJ, U.P-209721 (Name & Address of
the School) on 16.09.2026 and found that the ST. PAUL'S SCHOOL,
LALAKPUR, CHHIBRAMAU, KANNAUJ, U.P (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 01 year.

Dr. Singh, H.S.
CHC CBA
(Kannaui)

Signature with Seal :

Name

Designation

चिकित्सा अधीक्षक
सामुं स्वां केन चिब्रामा
जिला-कन्नौज

To

ST. PAUL'S SCHOOL
LALAKPUR, CHHIBRAMAU
KANNAUJ, U.P-209721

(Name & Address of the Institution)

WATER QUALITY TEST REPORT

Report Reference No: CHC/129

Date of Issue: 16/09/2026

1. GENERAL INFORMATION

Parameter	Details
Client Name	St. Paul's School, Chhibramau
Sample Source	RO Plant
Sample Location	Lalakupur, Chhibramau, Kannauj
Date & Time Sampled	15/09/2026 10.00 a.m
Sampled By	S.R.Singh H.S (CHC CHHIBRAMAU)
Date of Testing	15/09/2026

2. PHYSICAL & CHEMICAL ANALYSIS

Parameter	Unit	Observed Result	Standard Limit (Acceptable)	Status
Color	Color Units	Clear	Clear / Colorless	Pass
Odor	—	Unobjectionable	Unobjectionable	Pass
pH Value	—	7.2	6.5 – 8.5	Pass
Turbidity	NTU	0.8	< 1.0 NTU	Pass

Total Dissolved Solids (TDS)	mg/L	70	< 500 mg/L	Pass
Total Hardness (CaCO_3)	mg/L	150	< 200 mg/L	Pass
Chlorine (Free Residual)	mg/L	0.4	0.2 – 1.0 mg/L	Pass
Nitrate (NO_3)	mg/L	12	< 45 mg/L	Pass
Iron (Fe)	mg/L	0.1	< 0.3 mg/L	Pass

Tested By: S.R.Singh H.S (CHC CBR Kannauj)

Date: 16/09/2026

Q
16/09/26

प्रखारी चिकित्सा अधिकारी
आरु स. केन्द्र चिकित्सक
कन्नौज-कन्नौज